

Product Evaluation

RC649 | 0421

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: RC-649

Effective Date: April 1, 2021

Re-evaluation Date: April 2025

Product Name: Polyglass Modified Bitumen Roofing Systems Installed Over Concrete Decks

Manufacturer: Polyglass USA, Inc.
1111 W. Newport Center Drive
Deerfield Beach, FL 33442
(954) 233-1230

Mule-Hide Products, Inc.
1195 Prince Hall Dr.
Beloit, WI 53511

General Description:

- **Polyglass G2 Base** is an asphaltic, fiberglass reinforced base sheet with a sanded top surface.
- **Elastobase P** is a modified bitumen, polyester reinforced base sheet that may be used in hot asphalt, cold adhesive, mechanically fastened or self-adhered applications.
- **Elastobase V** is a modified bitumen coated fiberglass reinforced base sheet.
- **Elastoshield VP HT** is a modified bitumen coated fiberglass reinforced base sheet.
- **Modibase** is a modified bitumen, fiberglass reinforced base sheet.
- **Ply IV** is a modified bitumen coated heavyweight fiberglass reinforced ply sheet.
- **Ply VI** is a modified bitumen coated heavyweight fiberglass reinforced ply sheet.

- **Polybase V** is a torch applied, fiberglass reinforced, APP modified bitumen membrane with poly-film top and bottom surfaces.
- **Elastoflex SA V** is a nominal 60-mil (1.5-mm) thick, self-adhering, fiberglass reinforced modified bitumen membrane with a smooth top surface.
- **Elastoflex SA V FR** is a nominal 60-mil (1.5-mm) thick, self-adhering, fiberglass reinforced modified bitumen membrane with a smooth top surface and fire-retardant chemistry
- **Elastoflex SA V PLUS** is a nominal 80-mil (2.0-mm) thick, self-adhering, fiberglass reinforced modified bitumen membranes with a smooth top surface.
- **Elastoflex SA V PLUS FR** is a nominal 80-mil (2.0-mm) thick, self-adhering, fiberglass reinforced modified bitumen membrane with a smooth top surface and fire-retardant chemistry.
- **Elastoflex SA P** is a self-adhering, polyester reinforced modified bitumen membrane with a granule top surface.
- **Elastoflex SA P FR** is a self-adhering, polyester reinforced modified bitumen membranes with a granule top surface and fire-retardant chemistry.
- **Polyreflect** is a self-adhering, polymer, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
- **Elastoflex S6** is a torch, hot asphalt, or cold adhesive applied polyester reinforced, modified bitumen membranes with a polyethylene or sanded top surface.
- **Elastoflex S6 HP** is a torch, hot asphalt, or cold adhesive applied polyester reinforced, modified bitumen membranes with a polyethylene or sanded top surface.
- **Elastoflex S6 G** is a torch, hot asphalt, or cold adhesive applied polyester reinforced, modified bitumen membrane with a granule top surface.
- **Elastoflex S6 G FR** is a torch, hot asphalt, or cold adhesive applied polyester reinforced, modified bitumen membranes with a granule top surface and fire-retardant chemistry.
- **Elastoflex V** is a torch, hot asphalt, or cold adhesive applied fiberglass reinforced, modified bitumen membrane with a sanded top surface.
- **Elastoflex V G** is a torch, hot asphalt, or cold adhesive applied fiberglass reinforced, modified bitumen membrane with a granule top surface.
- **Elastoflex V G FR** is a torch, hot asphalt, or cold adhesive applied fiberglass reinforced, modified bitumen membranes with a granule top surface and fire-retardant chemistry.
- **Elastoshield TS G** is a torch, hot asphalt, or cold adhesive applied polyester reinforced, modified bitumen membrane with a granule top surface.
- **Elastoshield TS G FR** is a torch, hot asphalt, or cold adhesive applied polyester reinforced, modified bitumen membrane with a granule top surface and fire-retardant chemistry.
- **Polybianko** is a self-adhered, polyester reinforced, modified bitumen membrane with a reflective white film laminate on the top surface.
- **Polybond** is a torch applied polyester reinforced, modified bitumen membrane with a smooth or sanded top surface.
- **Polybond G** is a torch applied polyester reinforced, modified bitumen membrane with a granule top surface.
- **Polyflex** is a torch applied polyester reinforced, modified bitumen membranes with a smooth or sanded top surface.

- **Polyflex SA Base** is a self-adhered, fiberglass reinforced, APP modified bitumen base sheet.
- **Polyflex G** is a torch applied polyester reinforced, modified bitumen membrane with a granule top surface.
- **Polyflex G FR** is a torch applied polyester reinforced, modified bitumen membranes with a granule top surface and fire-retardant chemistry.
- **Polyflex SA P** is an elastomeric, polyester reinforced membrane consisting of an APP compound on the top layer and a self-adhesive compound on the bottom layer.
- **Polyflex SA P FR** is an elastomeric, polyester reinforced membranes consisting of an APP compound on the top layer, a self-adhesive compound on the bottom layer and fire-retardant chemistry.
- **Polyfresko G APP SA** is a self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face, and a reflective white granule top surface
- **Polyfresko G APP SA FR** is a self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face, a reflective white granule top surface and fire-retardant chemistry.
- **Polyfresko G SBS SA** is a self-adhered, polyester reinforced, SBS modified bitumen membrane with a self-adhering back face, and a reflective white granule top surface.
- **Polyfresko G SBS SA FR** is a self-adhered, polyester reinforced, SBS modified bitumen membrane with a self-adhering back face, a reflective white granule top surface and fire-retardant chemistry.
- **Polyfresko G SBS** is a hot asphalt applied SBS modified bitumen membrane with reflective white granules on the top surface.
- **Polyfresko G SBS FR** is a hot asphalt applied SBS modified bitumen membrane with reflective white granules on the top surface and fire-retardant chemistry.
- **Polyfresko G** is a torch applied APP modified bitumen membranes with reflective white granules on the top surface.
- **Polyfresko G FR** is a torch applied APP modified bitumen membrane with reflective white granules on the top surface and fire-retardant chemistry.
- **PolyKool** is a self-adhered, polyester reinforced, modified bitumen membranes with a reflective white film laminate on the top surface.
- **Polystick TU Max** is a self-adhered, rubberized asphalt waterproofing membrane.
- **Polystick TU Plus** is a self-adhered, fiberglass reinforced, rubberized asphalt waterproofing membrane with a polyester fabric on the top surface.

Mule-Hide Products Co., Inc. Products

- **Nail Base** is an SBS modified bitumen, fiberglass reinforced base sheet with a sand finish on the bottom surface and a polyolefin film top surface.
- **SA Base Sheet** is a nominal 60-mil (1.5-mm) thick, self-adhering, fiberglass reinforced modified bitumen membrane with a smooth top surface.
- **SA Base Sheet (FR)** is a nominal 60-mil (1.5-mm) thick, self-adhering, fiberglass reinforced modified bitumen membrane with a smooth top surface and fire-retardant chemistry
- **SA-SBS Cap Sheet** is a self-adhered, polyester reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.
- **SA-SBS Cap Sheet (FR)** is a self-adhered, polyester reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface, and fire-retardant chemistry.
- **SA-APP Cap Sheet** is a self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
- **SA-APP Cap Sheet (FR)** is a self-adhered, polyester reinforced, modified bitumen membrane with a self-adhering back face, a granule top surface, and fire-retardant chemistry.
- **SA-SBS KoolCap** is a self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.
- **SA-SBS KoolCap (FR)** is a self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.
- **SA-APP KoolCap** is a self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and granule top surface.
- **SA-APP KoolCap (FR)** is a self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
- **APP Torch Base Premier** is a torch applied, fiberglass reinforced, APP modified bitumen membrane with poly-film top and bottom surfaces.
- **APP Torch S Premier** is a torch applied polyester reinforced, modified bitumen membrane with a smooth or sanded top surface.
- **APP Torch G Premier** is a torch applied polyester reinforced, modified bitumen membrane with a granule top surface.
- **APP Torch G FR Premier** is a torch applied polyester reinforced, modified bitumen membranes with a granule top surface and fire-retardant chemistry.
- **APP Torch G KoolCap** is a torch applied APP modified bitumen membranes with reflective white granules on the top surface.
- **APP Torch G FR KoolCap** is a torch applied APP modified bitumen membrane with reflective white granules on the top surface and fire-retardant chemistry.

Limitations and Installation:**General Installation Requirements:**

All IRC and the IBC requirements must be satisfied, and manufacturer's installation instructions followed, unless otherwise specified by this product evaluation.

For All Applications: Roof decks, in which this product is to be installed upon, must be provided with positive drainage. A minimum roof slope after construction of 1/4" per foot is recommended.

Prime decks were required, in accordance with requirements and recommendations of the primer and deck manufacturer (if applicable). For re-roofing and re-cover applications, prime existing roof surfaces as necessary with Polyglass PG 100 asphalt primer or an asphalt primer meeting ASTM D-41 specification and allow to dry prior to installing the Polyglass roofing system.

The Following Notes Apply to the Systems Outlined Herein:

1. The roof decking must meet or exceed the uplift requirements of the IRC and IBC. Install as required for resistance to wind loads.
2. Roof framing members must be spaced a maximum of 24" o.c.
3. Unless otherwise noted, insulation adhesive application rates are as follows. Ribbon or bead width is at the time of application; the ribbons/beads must expand as noted in the manufacturer's published instructions.
 - Hot asphalt at 20-40 lbs/square.
 - Dow Insta Stik™ Quik Set Insulation Adhesive is continuous 3/4" to 1" wide ribbons, 12" o.c.
 - Millennium One-Step Foamable Adhesive in continuous 1/4" to 1/2" wide ribbons, 12" o.c.
 - Millennium PG-1 Pump Grade Adhesive in continuous 1/4" to 1/2" wide ribbons, 12" o.c.
 - OMG OlyBond 500 Adhesive in continuous 3/4" to 1" wide ribbons, 12" o.c. (PaceCart or SpotShot). *Note: OMG OlyBond 500 Green Adhesive may be used in any system listing OMG OlyBond 500 Adhesive.*
 - Polyset CR-20 in continuous 2-1/2"-3-1/2" wide ribbons, 12" o.c.
 - *Note: When multiple layer(s) of insulation and/or coverboard are installed in ribbon-applied adhesive, adhesive ribbons shall be staggered from layer-to-layer a distance of one-half the ribbon spacing.*
 - *Note: The maximum edge distance from the adhesive ribbon to the edge of the insulation board shall be not less than one-half the specified ribbons spacing.*
4. Unless otherwise noted, the insulation may be any polyisocyanurate, polystyrene, fiberboard, perlite and/or gypsum-based insulation board that meet the requirements of the IRC and IBC.
5. Bonded polyisocyanurate insulation boards shall be maximum 4' x 4'.

6. Unless otherwise noted, all base sheets specified in this report are metric.
7. Unless otherwise noted, all insulations are flat stock or taper board of the minimum thickness noted. Tapered polyisocyanurate at the following thickness limitations may be substituted with the following Maximum Design Pressure (MDP) limitations. In no case shall these values be used to 'increase' the MDP listings in the tables; rather if MDP listing below meets or exceeds that listed for a particular system in the tables, then the thinner board listed below may be used as a drop-in for the equivalent thicker material listed in the table:
 - Insta Stik™ Quik Set Insulation Adhesive: MDP -120.0 psf (min. 1/2" thick)
 - Millennium One-Step Foamable Adhesive: MDP -157.5 psf (min. 1/2" thick)
 - Millennium PG-1 Pump Grade Adhesive: MDP -157.5 psf (min. 1/2" thick)
 - OMG OlyBond 500 or OMG OlyBond Green Adhesive Fastener: MDP -45.0 psf (min. 1/2" Multi-Max FA-3)
 - OMG OlyBond 500 or OMG OlyBond Green Adhesive Fastener: MDP -315.0 psf (min. 1/2" ENRGY 3)
 - OMG OlyBond 500 or OMG OlyBond Green Adhesive Fastener: MDP -487.5 psf (min. 1/2" AC Foam-II)
 - Polyset CR-20: MDP -117.5 psf (min. 1" thick)

8. Appendix 1

| APPENDIX 1: ATTACHMENT REQUIREMENTS FOR WIND UPLIFT RESISTANCE | | | | | |
|---|-------------|---------------------|--------------------------|--------------------------------------|-------------|
| Table | Deck | Assembly No. | Application | Description | Page |
| 1A | Concrete | C-1 – C-44 | New or Reroof (Tear-Off) | Bonded Insulation, Bonded Roof Cover | 10-29 |
| 1B | Concrete | C-45 – C-50 | New or Reroof (Tear-Off) | Non-Insulated, Bonded Roof Cover | 30-32 |

9. Unless otherwise noted, refer to the following references for bonded base, ply or cap sheet applications.

| TABLE 1: POLYGLASS ROOF COVERS | | | |
|--|-------------|--|---------------------------------|
| Reference | Layer | Material | Application |
| BP-AA (Base and Ply sheets, Asphalt-Applied) | Base | Polyglass G2 Base, Modibase | Hot asphalt at 20-40 lbs/square |
| | Ply | ASTM D2178, Type IV, or VI | |
| SBS-CA1 | Base | Elastobase V (sand/sand), Elastoshield VP HT, Elastobase P, Elastoflex V, Elastoflex S6, Elastoflex S6 HP, Elastoshield TS | PG350 at 1.5-2.0 gal/square |
| | Cap | Elastoflex V, Elastoflex V G, Elastoflex V G FR, Elastoflex S6, Elastoflex S6 HP, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS, Elastoshield TS G, Elastoshield TS G FR, Polyfresko G SBS (sand-backed), Polyfresko G SBS FR (sand-backed) | |
| SBS-AA (SBS, Asphalt-Applied) | Base or Ply | Elastobase V (sand/sand or poly/sand), Elastoshield VP HT, Elastobase P (sand/sand or poly/sand), Elastoflex V, Elastoflex S6, Elastoflex S6 HP, Elastoshield TS, Elastoshield TS FR | Hot asphalt at 20-40 lbs/square |
| | Cap | Elastoflex V, Elastoflex V G, Elastoflex V G FR, Elastoflex S6, Elastoflex S6 HP, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS, Elastoshield TS FR, Elastoshield TS G, Elastoshield TS G FR, Polyfresko G SBS (sand-backed), Polyfresko G SBS FR (sand-backed) | |
| SBS-TA (SBS, Torch-Applied) | Base or Ply | Elastobase V (sand/poly or poly/poly), Elastoshield VP HT, Elastobase P, Elastoflex V, Elastoflex S6, Elastoflex S6 HP, Elastoshield TS, Elastoshield TS FR | Torch-Applied |
| | Cap | Elastoflex V, Elastoflex V G, Elastoflex V G FR, Elastoflex S6, Elastoflex S6 HP, Elastoflex S6 G, Elastoflex S6 G FR, Elastoshield TS G, Elastoshield TS G FR, Polyfresko G SBS (poly-film backed), Polyfresko G SBS FR (poly-film backed) | |
| SBS-SA (SBS, Self-Adhering) | Base or Ply | Elastoflex SA V, Elastoflex SA V PLUS, Elastoflex SA V FR, Elastoflex SA V PLUS FR | Self-Adhering |
| | Cap | Elastoflex SA P, Elastoflex SA P FR, Polyreflect | |
| APP-CA1 | Cap | Polyflex G, Polyflex G FR, APP Torch G, APP Torch G (FR) | PG350 at 1.5-2.0 gal/square |
| APP-TA (APP, Torch-Applied) | Base or Ply | Polybase V, Polyflex, Polybond | Torch-Applied |
| | Cap | Polyflex, Polyflex G, Polyflex G FR, Polybond, Polybond G, Polyfresko G, Polyfresko G FR | |
| APP-SA (APP, Self-Adhering) | Cap | Polyflex SA P, Polyflex SA P FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Polykool, Polybianko | Self-Adhering |

10. Mule Hide Counterparts

| TABLE 2: MULE-HIDE COUNTERPARTS | |
|--|--------------------------------|
| POLYGLASS [MANUFACTURER] | MULE-HIDE [LABELER] |
| Polybase V | APP Torch Base Premier |
| Polybond | APP Torch Base/Cap |
| Polybond G | APP Torch G |
| Elastobase V or Elastoshield VP HT | Nail Base |
| Elastobase P | N/A |
| Elastoflex SA V | SA Base Sheet |
| Elastoflex SA V FR | SA Base Sheet (FR) |
| Elastoflex SA P | SA-SBS Cap Sheet |
| Elastoflex SA P FR | SA-SBS Cap Sheet (FR) |
| Elastoflex S6 G | N/A |
| Polyflex | APP Torch S Premier |
| Polyflex G | APP Torch G Premier |
| Polyflex G FR | APP Torch G FR Premier |
| Polyfresko G | APP Torch G KoolCap |
| Polyfresko G FR | APP Torch G FR KoolCap |
| Polyflex SA P | SA-APP Cap Sheet |
| Polyflex SA P FR | SA-APP Cap Sheet (FR) |
| Polyfresko G SBS SA | SA-SBS KoolCap |
| Polyfresko G SBS SA FR | SA-SBS KoolCap FR |
| Polyfresko G APP SA | SA-APP KoolCap |
| Polyfresko G APP SA FR | SA-APP KoolCap (FR) |

11. Apply any of the following coatings to the top roof membrane. Apply the coatings in accordance with the manufacturer's installation instructions.
- PG100 – A general all-purpose penetrating asphalt primer.
 - PG200 – Non-Fibered Roof Coating or Mule-Hide 111 Non-Fibrated Roof Coating.
 - PG300 – Fibered Roof Coating or Mule-Hide 102 Fibrated Roof Coating.
 - PG350 – A cold-applied bonding adhesive.
 - PG600 – Non-Fibered Aluminum Roof Coating or Mule-Hide 416 Standard Non-Fibrated Aluminum Roof Coating.
 - PG650 – Fibered Aluminum Roof Coating or Mule-Hide 406 Standard Fibrated Aluminum Roof Coating.
 - PG700 – Elastomeric Roof Coating in white or tinted; PG700 QS Quick drying Reflective Roof Coating in white or tinted; KM Acryl 25 white or tinted; KM Acryl 25 QS white or tinted.
 - PG800 – Non-Fibered Asphalt Emulsion Roof Coating or Mule-Hide 311 Emulsion Non-Fibrated.
 - Polyplus 60 – Premium Non-Fibered Aluminum Roof Coating or Mule-Hide 410 Premium Non-Fibrated Aluminum Roof Coating.
 - Polyplus 65 – Premium Fibered Aluminum Roof Coating or Mule-Hide 401 Premium Fibrated Aluminum Roof Coating.
 - Polybrite 70 – Premium Grade Elastomeric Roof Coating in white or tinted; Polybrite 70 QS Quick drying Elastomeric Roof Coating in white or tinted; KM Acryl 15 in white or tinted; KM Acryl 15 QS in white or tinted.
 - Polybrite 71 HS – A premium grade, high solids, water-based elastomeric coating in white or tinted; KM Acryl 40 HS in white or tinted.
 - Polybrite 75 – A high tensile, superior grade water-based elastomeric coating in white or tinted; KM Acryl 85 in white or tinted.
 - Polybrite 90 – High Solids Silicone Roof Coating in white or tinted; PS #250 High Solids Silicone Roof Coating in white or tinted.
 - Polybrite 95 – Silicone Roof Coating in white or tinted; PS #220 High Solids Silicone Roof Coating in white or tinted.
 - Polybrite 97X Primer – A two component, 1 to 1 ratio, water-based epoxy primer; KM Epoxy Primer.
 - PolyBrite 95.1 – Is a silicone based, white or tinted, liquid applied roof cover.
 - PolyBrite 90.1 – Is a silicone based, white or tinted, liquid applied roof cover.
 - PolyBrite 98 – Is a water-based, one-part primer/bleed blocker.
 - PolyBrite 84 – Is a rust inhibitive primer.
 - Turbo-Set™ – A two-component, water-based, elastomeric coating.

Limitations and Installation: Installation must be in accordance with the following assemblies:

| TABLE 1A: POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|---|-------------------------|------|--------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-1 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, ENRGY 3, H-Shield, Polytherm-H or Approved EPS 1.0 pcf in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | APP-TA | None | APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -120.0 | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in rows 12" o.c. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|---|---|-------------------------|------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-2 | Min. 2500 psi Structural Concrete | Min. 2.0" Approved EPS 2.0 pcf in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | (Optional) Min. 1/2 High Density Fiberboard Roof Insulation or min. 1/4" DensDeck ² in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-SA | None | SBS-TA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -120.0 | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in rows 12" o.c. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.
2. For self-adhering applications directly to non-prime DensDeck, Polyglass requires an application of ASTM D-41 Asphalt Primer.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|--|-------------------------|------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-3 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, ENRGY 3, H-Shield, Polytherm-H, Multi-Max FA-3, ISO 95+ GL or Approved EPS 2.0 pcf in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | (Optional) Additional layer(s) of base insulation in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-SA | None | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -120.0 | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in rows 12" o.c. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|--|-------------------------|------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-4 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, ENRGY 3, H-Shield, Polytherm-H, Multi-Max FA-3 or ISO 95+ GL in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/4" DensDeck ² or DensDeck Prime in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-SA | None | SBS-TA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -127.5 | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in rows 12" o.c. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.
2. For self-adhering applications directly to non-prime DensDeck, Polyglass requires an application of ASTM D-41 Asphalt Primer.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|---|---|-------------------------|------|--------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-5 | Min. 2500 psi Structural Concrete | Min. 1" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, H-Shield or Polytherm-H in Millennium One Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, Polyset CR-20, Insta Stik Quik Set Insulation Adhesive or OlyBond 500 Adhesive (PaceCart or SpotShot) | Min. 0.25" SECUROCK Gypsum-Fiber Roof Board, DEXcell FA Glass Mat Roof Board or DensDeck Prime in Millennium One Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, Polyset CR-20, Insta Stik Quik Set Insulation Adhesive or OlyBond 500 Adhesive (PaceCart or SpotShot) | SBS-CA1 | None | SBS-CA1 or APP-CA1 |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -127.5 | | Millennium One Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, Polyset CR-20, Insta Stik Quik Set Insulation Adhesive or OlyBond 500 Adhesive (PaceCart or SpotShot) in rows 12" o.c. | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|--|-------------------------|------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-6 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, ENRGY 3, H-Shield, Polytherm-H, Multi-Max FA-3 or ISO 95+ GL in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/4" DensDeck ² or DensDeck Prime in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-SA | None | SBS-TA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -150.0 | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in rows 12" o.c. | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.
- For self-adhering applications directly to non-prime DensDeck, Polyglass requires an application of ASTM D-41 Asphalt Primer.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | | |
|---|-----------------------------------|---|-----|--|--------|------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | | |
| | | Base | Top | Base | Ply | Cap | |
| C-7 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, Polytherm, ENRGY 3, H-Shield, Polytherm-H, Multi-Max FA-3 or ISO 95+ GL in Millennium One-Step Foamable Adhesive | | (Optional) Additional layer(s) of base insulation in Millennium One-Step Foamable Adhesive | SBS-SA | None | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | | |
| -157.5 | | Millennium One-Step Foamable Adhesive in rows 12" o.c. | | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | | | |
|---|-----------------------------------|--|---|-----|---|------------------|-----------------------------|------------------|
| Assembly No. | Substrate | Vapor Barrier | Insulation | | Roof Cover ¹ | | | |
| | | | Base | Top | Base | Ply | Cap | |
| C-8 | Min. 2500 psi Structural Concrete | Elastoflex SA P, self-adhered | Min. 1.5" ACFoam-II, Polytherm, ENRGY 3, H-Shield, Polytherm-H, Multi-Max FA-3, ISO 95+ GL or Approved EPS 1.0 pcf in Millennium One-Step Foamable Adhesive | | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board in Millennium One-Step Foamable Adhesive | APP-TA or SBS-AA | (Optional) APP-TA or SBS-AA | APP-TA or SBS-AA |
| Design Pressure (psf) | | Insulation Attachment | | | | | | |
| -157.5 | | Millennium One-Step Foamable Adhesive in rows 12" o.c. | | | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|--|-------------------------|------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-9 | Min. 2500 psi Structural Concrete | Min. 1.5" Approved EPS 2.0 pcf in Insta Stik™ Quik Set Insulation Adhesive | Min. 1/2" High Density Wood Fiberboard in Insta Stik™ Quik Set Insulation Adhesive | SBS-SA | None | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -157.5 | | Insta Stik™ Quik Set Insulation Adhesive in rows 12" o.c. | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|--|--|--|-------------------------|------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-10 | Min. 2500 psi Structural Concrete primed with PG100 or ASTM D41 Primer | Min. 2.0" ACFoam-II, Polytherm, ENRGY 3, H-Shield, Polytherm-H, Multi-Max FA-3, ISO 95+ GL or Approved EPS 1.0 pcf in hot asphalt, Insta Stik™ Quik Set Insulation Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One-Step Foamable Adhesive or Polyset CR-20 | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board in Insta Stik™ Quik Set Insulation Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One Step Foamable Insulation Adhesive or Polyset CR-20 | SBS-SA | None | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -225.0 | | Insta Stik™ Quik Set Insulation Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One Step Foamable Insulation Adhesive or Polyset CR-20 in rows 12" o.c. | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|--|---|--|-------------------------|------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-11 | Min. 2500 psi Structural Concrete primed with PG100 or ASTM D41 Primer | Min. 1.5" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, ENRGY 3, H-Shield, Polytherm-H, H-Shield CG, Multi-Max FA-3 or Approved EPS 2.0 pcf in Millennium One-Step Foamable Adhesive | (Optional) Additional layer(s) of base insulation in Millennium One-Step Foamable Adhesive | SBS-SA | None | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -232.5 | | Millennium One Step Foamable Insulation Adhesive in rows 12" o.c. | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|---|---|-------------------------|------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-12 | Min. 2500 psi Structural Concrete | Min. 2.0" ACFoam-IV or min. 1.5" Ultra-Max or Multi-Max FA-3 or min. 1.3" ACFoam-III, Polytherm G or min. 1.0" ISO 95+ GL, H-Shield, Polytherm-H, H-Shield CG, JM ISO 3 or ENRGY 3 in Polyset CR-20 | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board in Polyset CR-20 | SBS-SA | None | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -240.0 | | Polyset CR-20 in continuous 1.5" beads/ribbons spaced 12" o.c. | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | | |
|---|--|--------------------------------|---|--|-------------------------|------|--------------------------|
| Assembly No. | Substrate | Vapor Barrier | Insulation | | Roof Cover ¹ | | |
| | | | Base | Top | Base | Ply | Cap |
| C-13 | Min. 2500 psi Structural Concrete primed with PG100 or ASTM D41 Primer | Elastoflex SA P, self-adhered | Min. 1.5" ACfoam-II, ACfoam-III, Polytherm, Polytherm G, ENRGY 3, H-Shield, Polytherm-H, H-Shield CG, Multi-Max FA-3 or Approved EPS 2.0 pcf in Polyset CR-20 | (Optional) Additional layer(s) of base insulation in Polyset CR-20 | SBS-SA | None | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | | |
| -250.0 | | Polyset CR-20 in rows 12" o.c. | | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | | |
|---|-----------------------------------|--|--|-------------------------|------|--------------------------|--|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | | |
| | | Base | Top | Base | Ply | Cap | |
| C-14 | Min. 2500 psi Structural Concrete | Min. 0.75" Approved EPS 1.0 pcf in Polyset CR-20 | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board or DensDeck ² in Polyset CR-20 | SBS-SA | None | SBS-SA, APP-SA or APP-TA | |
| Design Pressure (psf) | | Insulation Attachment | | | | | |
| -255.0 | | Polyset CR-20 in rows 12" o.c. | | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.
2. For self-adhering applications directly to non-prime DensDeck, Polyglass requires an application of ASTM D-41 Asphalt Primer.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|--|---|------|-------------------------|------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-15 | Min. 2500 psi Structural Concrete primed with PG100 or ASTM D41 Primer | Min. 1.5" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, ENRGY 3, H-Shield, Polytherm-H, H-Shield CG, Multi-Max FA-3 or Approved EPS 2.0 pcf in Polyset CR-20 | None | SBS-SA | None | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -262.5 | | Polyset CR-20 in rows 12" o.c. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|---|---|-------------------------|-----------------------------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-16 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, Polytherm, ENRGY 3, H-Shield, Polytherm-H, Multi-Max FA-3, ISO 95+ GL or Approved EPS 1.0 pcf in Polyset CR-20 | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board in Polyset CR-20 | APP-TA or SBS-AA | (Optional) APP-TA or SBS-AA | APP-TA or SBS-AA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -262.5 | | Polyset CR-20 in rows 12" o.c. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|---|---|-------------------------|------|--------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-17 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, Polytherm, ENRGY 3, H-Shield, Polytherm-H, Multi-Max FA-3, ISO 95+ GL or Approved EPS 1.0 pcf in Polyset CR-20 | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board in Polyset CR-20 | APP-TA | None | APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -262.5 | | Polyset CR-20 in rows 12" o.c. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|---|-------------------------------|-----------------------------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-18 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in Insta Stik™ Quik Set Insulation Adhesive | Min. 1/4" DensDeck Prime in Insta Stik™ Quik Set Insulation Adhesive | SBS-TA or APP-TA | (Optional) SBS-TA or APP-TA | SBS-TA or APP-TA |
| C-19 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in Insta Stik™ Quik Set Insulation Adhesive | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board or DEXcell FA Glass Mat Roof Board in Insta Stik™ Quik Set Insulation Adhesive | SBS-TA or APP-TA | (Optional) SBS-TA or APP-TA | SBS-TA or APP-TA |
| C-20 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/4" DensDeck Prime in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-TA or APP-TA | (Optional) SBS-TA or APP-TA | SBS-TA or APP-TA |
| C-21 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board or DEXcell FA Glass Mat Roof Board in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-TA or APP-TA | (Optional) SBS-TA or APP-TA | SBS-TA or APP-TA |
| C-22 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in Millennium One-Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive | Min. 1/4" DensDeck Prime in Millennium One-Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive | SBS-TA or APP-TA | (Optional) SBS-TA or APP-TA | SBS-TA or APP-TA |
| C-23 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in Millennium One-Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board or DEXcell FA Glass Mat Roof Board in Millennium One-Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive | SBS-TA or APP-TA | (Optional) SBS-TA or APP-TA | SBS-TA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -282.5 (only with C-18) | | Insta Stik™ Quik Set Insulation Adhesive in rows 12" o.c. | | | | |
| -322.5 (only with C-19) | | | | | | |
| -282.5 (only with C-20) | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in rows 12" o.c. | | | | |
| -322.5 (only with C-21) | | | | | | |
| -282.5 (only with C-22) | | Millennium One Step Foamable Insulation Adhesive or Millennium PG-1 Pump Grade Adhesive in rows 12" o.c. | | | | |
| -322.5 (only with C-23) | | | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|---|--|-------------------------|-----------------------------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-24 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in Polyset CR-20 | Min. 1/4" DensDeck Prime in Polyset CR-20 | SBS-TA or APP-TA | (Optional) SBS-TA or APP-TA | SBS-TA or APP-TA |
| C-25 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in Polyset CR-20 | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board or DEXcell FA Glass Mat Roof Board in Polyset CR-20 | SBS-TA or APP-TA | (Optional) SBS-TA or APP-TA | SBS-TA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -282.5 (only with C-24) | | Polyset CR-20 in rows 12" o.c. | | | | |
| -322.5 (only with C-25) | | | | | | |

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | | |
|---|-----------------------------------|---|--|--|------------------------------------|------|------------------|
| Assembly No. | Substrate | Insulation | | | Roof Cover ¹ | | |
| | | Vapor Barrier | Base | Top | Base | Ply | Cap |
| C-26 | Min. 2500 psi Structural Concrete | None | Min. 1.5" ACFoam-II, H-Shield, Polytherm or Polytherm H in Polyset CR-20 | (Optional) additional layer(s) of base insulation in Polyset CR-20 | SBS-SA or Polyflex SA Base | None | SBS-TA or APP-TA |
| C-27 | Min. 2500 psi Structural Concrete | None | Min. 1.0" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, Insta Stik™ Quik Set Insulation Adhesive or Polyset CR-20 | (Optional) additional layer(s) of base insulation in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, Insta Stik™ Quik Set Insulation Adhesive or Polyset CR-20 PRIMER: PG100 | Polyflex SA Base primed with PG100 | None | SBS-SA or APP-SA |
| Design Pressure (psf) | | Insulation Attachment | | | | | |
| -122.5 (only with C-26) | | Polyset CR-20 in rows 12" o.c. | | | | | |
| -170.0 (only with C-27) | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, Insta Stik™ Quik Set Insulation Adhesive or Polyset CR-20 in rows 12" o.c. | | | | | |

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|--|------------------------------------|------------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-28 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, H-Shield, ENRGY 3, Polytherm or Polytherm H in Insta Stik™ Quik Set Insulation Adhesive | Min. 1/4" DensDeck Prime in Insta Stik™ Quik Set Insulation Adhesive | SBS-SA | None | SBS-SA |
| C-29 | Min. 2500 psi Structural Concrete | Min. 1.0" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, Insta Stik™ Quik Set Insulation Adhesive or Polyset CR-20 | Min. 1/4" DensDeck Prime, DEXcell FA Glass Mat Roof Board or SECUROCK Gypsum-Fiber Roof Board in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, Insta Stik™ Quik Set Insulation Adhesive or Polyset CR-20 PRIMER: PG100 | Polyflex SA Base primed with PG100 | None | SBS-SA or APP-SA |
| C-30 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, H-Shield, ENRGY 3, ISO 95+ GL, Polytherm or Polytherm H in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/4" DensDeck Prime in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-SA | None | SBS-SA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -72.5 (only with C-28) | | Insta Stik™ Quik Set Insulation Adhesive in rows 12" o.c. | | | | |
| -172.5 (only with C-29) | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, Insta Stik™ Quik Set Insulation Adhesive or Polyset CR-20 in rows 12" o.c. | | | | |
| -72.5 (only with C-30) | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in rows 12" o.c. | | | | |

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|--|-------------------------------|-----------------------------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-31 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, H-Shield, ENRGY 3, Ultra-Max, Mult Max FA-3, ISO 95+ GL, Polytherm, Polytherm G or Polytherm H in Polyset CR-20 | Min. 1/4" DensDeck Prime in Polyset CR-20 | SBS-SA or Polyflex SA Base | None | APP-TA |
| C-32 | Min. 2500 psi Structural Concrete | Min. 1.5" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in Millennium One-Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive | Min. 1/4" DensDeck Prime in Millennium One-Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive | SBS-SA | (Optional) SBS-TA or APP-TA | SBS-TA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -240.0 (only with C-31) | | Polyset CR-20 in rows 12" o.c. | | | | |
| -282.5 (only with C-32) | | Millennium One-Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive in rows 12" o.c. | | | | |

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|---|---|-------------------------------|--------------------|--------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-33 | Min. 2500 psi Structural Concrete | Min. 1.0" ACFoam-II, ACFoam-III, ENRGY 3, H-Shield, Polytherm, Polytherm G or Polytherm H in Insta Stik™ Quik Set Insulation Adhesive, Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) or Polyset CR-20 | Min. 1/4" DensDeck Prime, DEXcell FA Glass Mat Roof Board or SECUROCK Gypsum-Fiber Roof Board in Insta Stik™ Quik Set Insulation Adhesive, Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) or Polyset CR-20 | SBS-CA 1 | SBS-CA1 | SBS-CA1 |
| C-34 | Min. 2500 psi Structural Concrete | Min. 1.0" ACFoam-II, ACFoam-III, H-Shield, Polytherm, Polytherm G or Polytherm H in Insta Stik™ Quik Set Insulation Adhesive, Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) or Polyset CR-20 | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board, DensDeck Prime or DEXcell FA Glass Mat Roof Board in Insta Stik™ Quik Set Insulation Adhesive, Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) or Polyset CR-20 | SBS-CA1 | (Optional) SBS-CA1 | SBS-CA1 or APP-CA1 |
| C-35 | Min. 2500 psi Structural Concrete | Min. 1.0" ENRGY 3, H-Shield or Polytherm H in Insta Stik™ Quik Set Insulation Adhesive, Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) or Polyset CR-20 | Min. 1/4" DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board in Insta Stik™ Quik Set Insulation Adhesive, Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) or Polyset CR-20 | SBS-CA1 | None | SBS-CA1 |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -75.0 (only with C-33) | | Insta Stik™ Quik Set Insulation Adhesive, Millennium One-Step Foamable Adhesive, Millennium PG-1 Pump Grade Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) or Polyset CR-20 in rows 12" o.c. | | | | |
| -127.5 (only with C-34) | | | | | | |
| -232.5 (only with C-35) | | | | | | |

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|--|-------------------------|--------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-36 | Min. 2500 psi Structural Concrete | Min. 2.0" H-Shield or Polytherm-H in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/2" DensDeck ² or DuraGuard Roof Board in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-SA | SBS-SA | SBS-SA or APP-SA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -330.0 | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in rows 12" o.c. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.
2. For self-adhering applications directly to non-prime DensDeck, Polyglass requires an application of ASTM D-41 Asphalt Primer.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|--|--|--|-------------------------|-------------------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-37 | Min. 2500 psi Structural Concrete primed with PG100 or ASTM D41 Primer | Min. 2.0" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, H-Shield, Polytherm-H, ENRGY 3 or Multi-Max FA-3 in hot asphalt | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board (primed with PG100 or ASTM D41 Primer) in hot asphalt | SBS-SA | (Optional) SBS-SA | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -350.0 | | Hot asphalt at a rate of 25 lbs/square. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|--|-------------------------|--------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-38 | Min. 2500 psi Structural Concrete | Min. 2.0" H-Shield or Polytherm-H in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/2" DensDeck ² or DuraGuard Roof Board in OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-SA | SBS-SA | SBS-SA or APP-SA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -375.0 | | OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in rows 6" o.c. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.
2. For self-adhering applications directly to non-prime DensDeck, Polyglass requires an application of ASTM D-41 Asphalt Primer.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|-----------------------------------|--|--|-------------------------|-----------------------------|------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-39 | Min. 2500 psi Structural Concrete | Min. 2.0" ACFoam-II, Polytherm a, H-Shield, Polytherm, ENRGY 3 or Approved EPS 1.0 pcf in Insta Stik™ Quik Set Insulation Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One Step Foamable Insulation Adhesive or Polyset CR-20 | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board in Insta Stik™ Quik Set Insulation Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One Step Foamable Insulation Adhesive or Polyset CR-20 | SBS-AA or APP-TA | (Optional) SBS-AA or APP-TA | SBS-AA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -442.5 | | Insta Stik™ Quik Set Insulation Adhesive, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot), Millennium One Step Foamable Insulation Adhesive or Polyset CR-20 in rows 12" o.c. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|--|---|--|-------------------------|------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-40 | Min. 2500 psi Structural Concrete primed with PG100 or ASTM D41 Primer | Min. 1.5" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, ENRGY 3, H-Shield, Polytherm-H, H-Shield CG, Multi-Max FA-3 or Approved EPS 2.0 pcf in hot asphalt | (Optional) Additional layer(s) of base insulation in hot asphalt | SBS-SA | None | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -480.0 | | Hot asphalt at a rate of 20-40 lbs/square. | | | | |

Footnote:

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|--|--|---|-------------------------|-------------------|--------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-41 | Min. 2500 psi Structural Concrete primed with PG100 or ASTM D41 Primer | Min. 2.0" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, ENRGY 3 or Approved EPS 1.0 pcf in hot asphalt, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board in hot asphalt, OlyBond 500, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-AA | (Optional) SBS-AA | SBS-AA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -495.0 | | Hot asphalt, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in 1.0 gal/square. | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|--|---|---|--------------------------|-------------------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-42 | Min. 2500 psi Structural Concrete primed with PG100 or ASTM D41 Primer | None | Min. 3/4" FescoBoard in hot asphalt | SBS-AA, SBS-TA or APP-TA | (Optional) SBS-AA | SBS-AA, SBS-TA or APP-TA |
| | | | Min. 1/2" Structodek High Density Fiberboard Roof Insulation in hot asphalt | | | |
| | | | Min. 1/4" DensDeck Prime in hot asphalt | | | |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -277.5 | | Hot asphalt in 20-40 lbs/square for FescoBoard. | | | | |
| -277.5 < P ≤ -285.0 | | Hot asphalt in 20-40 lbs/square for Structodek High Density Fiberboard Roof Insulation. | | | | |
| -285.0 < P ≤ -510.0 | | Hot asphalt in 20-40 lbs/square for DensDeck Prime. | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|---|--|--|-------------------------|-------------------|--------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-43 | Min. 2500 psi Structural Concrete primed with PG100 or ASTM D41 Primer (Primed if using Hot Asphalt) | Min. 2.0" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, ENRGY 3 or Approved EPS 1.0 pcf in hot asphalt, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board in hot asphalt, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | APP-TA | (Optional) APP-TA | APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -536.5 | | Hot asphalt, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in 1.0 gal/square. | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

| TABLE 1A (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, BONDED INSULATION, BONDED ROOF COVER | | | | | | |
|---|---|--|---|-------------------------|-------------------|--------------------------|
| Assembly No. | Substrate | Insulation | | Roof Cover ¹ | | |
| | | Base | Top | Base | Ply | Cap |
| C-44 | Min. 2500 psi Structural Concrete primed with PG100 or ASTM D41 Primer (Primed if using Hot Asphalt) | Min. 2.0" ACFoam-II, ACFoam-III, Polytherm, Polytherm G, ENRGY 3 or Approved EPS 1.0 pcf in hot asphalt, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | Min. 1/4" SECUROCK Gypsum-Fiber Roof Board (primed with PG100 or ASTM D41 Primer) in hot asphalt, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) | SBS-SA | (Optional) SBS-SA | SBS-SA, APP-SA or APP-TA |
| Design Pressure (psf) | | Insulation Attachment | | | | |
| -543.5 | | Hot asphalt, OlyBond 500 Adhesive, OlyBond 500 Green Adhesive (PaceCart or SpotShot) in 1.0 gal/square. | | | | |

Footnote:

- For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1B: POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, NON-INSULATED, BONDED ROOF COVER | | | |
|---|-----------------------------------|------|--------------------|
| Assembly No. | Roof Cover ¹ | | |
| | Base | Ply | Cap |
| C-45 | SBS-CA1 | None | SBS-CA1 or APP-CA1 |
| Design Pressure (psf) | Substrate | | Primer |
| -105.0 | Min. 2500 psi Structural Concrete | | None |

Footnote:

1. For roof cover installation, refer to Table 1 above.

| TABLE 1B (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, NON-INSULATED, BONDED ROOF COVER | | | |
|---|-----------------------------------|------|-----------------------------------|
| Assembly No. | Roof Cover ¹ | | |
| | Base | Ply | Cap |
| C-46 | Polyflex SA Base | None | SBS-SA or APP-SA |
| Design Pressure (psf) | Substrate | | Primer |
| -117.5 | Min. 2500 psi Structural Concrete | | Approved PG100 or ASTM D41 Primer |

Footnote:

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1B (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, NON-INSULATED, BONDED ROOF COVER | | | |
|---|-----------------------------------|-------------------------------------|-----------------------------------|
| Assembly No. | Roof Cover ¹ | | |
| | Base | Ply | Cap |
| C-47 | SBS-SA | (Optional) SBS-SA, SBS-TA or APP-TA | SBS-SA, APP-SA, SBS-TA or APP-TA |
| Design Pressure (psf) | Substrate | | Primer |
| -315.0 | Min. 2500 psi Structural Concrete | | Approved PG100 or ASTM D41 Primer |

Footnote:

1. For roof cover installation, refer to Table 1 above.

| TABLE 1B (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, NON-INSULATED, BONDED ROOF COVER | | | |
|---|-----------------------------------|------|-----------------------------------|
| Assembly No. | Roof Cover ¹ | | |
| | Base | Ply | Cap |
| C-48 | None | None | SBS-TA |
| Design Pressure (psf) | Substrate | | Primer |
| -495.0 | Min. 2500 psi Structural Concrete | | Approved PG100 or ASTM D41 Primer |

Footnote:

1. For roof cover installation, refer to Table 1 above.

Limitations and Installation:

| TABLE 1B (CONTINUED): POLYGLASS MODIFIED BITUMEN – NEW CONSTRUCTION OR REROOF (TEAR-OFF) CONCRETE DECK, NON-INSULATED, BONDED ROOF COVER | | | |
|---|---|---|-----------------------------------|
| Assembly No. | Roof Cover ¹ | | |
| | Base | Ply | Cap |
| C-49 | Polyglass G2 Base, Elastobase V, Elastoshield VP HT (sand surfaced), Elastobase P, Elastoflex V, Elastoflex S6 or Elastoflex S6 HP applied in hot asphalt at a rate of 20-40 lbs/square | (Optional) Ply IV, Ply VI, Elastobase V, Elastoshield VP HT (sand surfaced), Elastobase P, Elastoflex V, Elastoflex S6 or Elastoflex S6 HP applied in hot asphalt at a rate of 20-40 lbs/square | SBS-AA |
| C-50 | Elastobase V, Elastoshield VP HT (poly surfaced), Elastoflex V, Elastoflex S6, Elastoflex S6 HP, Polybase V, Polybond or Polyflex, torch-applied | (Optional) Elastobase V, Elastoshield VP HT (poly surfaced), Elastoflex V, Elastoflex S6, Elastoflex S6 HP, Polybase V, Polyflex or Polybond, torch-applied | SBS-TA or APP-TA |
| Design Pressure (psf) | Substrate | | Primer |
| -622.5 | Min. 2500 psi Structural Concrete | | Approved PG100 or ASTM D41 Primer |

Footnote:

1. For roof cover installation, refer to Table 1 above.

Note: Keep the manufacturer’s installation instructions at the job site during the installation. Use corrosion resistant fasteners as specified in the IRC and the IBC.