





- 1** WOOD NAILERS (BY OTHERS) MUST BE SECURELY FASTENED. FACTORY MUTUAL'S PROPERTY LOSS PREVENTION DATA SHEET 1-49 IS A REFERENCE FOR SECUREMENT CRITERIA.
- 2** 1-1/4" RING SHANK NAILS FOR WOOD SUBSTRATE. CONTINUOUS CLEAT MUST BE FASTENED 12" O.C. AND ADJOINING SECTIONS OF CONTINUOUS CLEAT SHALL BE LAPPED 1". THE DRIP EDGE FASCIA FLANGE MUST BE FASTENED 6" O.C. INTO THE PRE-PUNCHED HOLES WITH NO BUCKLING OR BOWING OF THE FLANGE.
- 3** INSTALL T-JOINT PATCHES AT T-JOINT INTERSECTIONS OF 60-MIL AND THICKER TPO REINFORCED OR TPO SA. FOR TPO FLEECE BACK, 115-MIL AND THICKER, T-JOINTS ARE REQUIRED. REFER TO T-JOINT PATCH DETAILS FOR ADDITIONAL INFORMATION.
- 4** AT FIELD TO WALL SEAM TRANSITIONS, INSTALL A T-PATCH CENTERED OVER THE TRANSITION. REFER TO DETAIL **TP-WF-C201** FOR ADDITIONAL INFORMATION
- 5** APPROX. 1/8" BEAD OF CUT-EDGE SEALANT IS REQUIRED ON CUT EDGES OF TPO REINFORCED MEMBRANE
- 6** WHEN USING TPO FLEECE BACK OR SELF-ADHERING MEMBRANE, END LAP SEAMS MUST BE OVERLAID WITH MIN. 6" WIDE TPO REINFORCED MEMBRANE. REFER TO DETAILS **TP-SM-C904**, **TP-SM-C905**, **TP-SM-C906**
- 7** SUPPLEMENTAL WOOD NAILER CONDITIONS OCCUR ON METAL RETROFITS: REFER TO APPLICABLE DETAILS **TP-EM-C121**, **TP-EM-C122**, **TP-EM-C125**, OR **TP-EM-C126**

**APPLICABLE FIELD MEMBRANE (AND SYSTEMS)**  
 TPO REINFORCED (ADHERED) (MECHANICALLY ATTACHED) (INDUCTION WELDED)  
 TPO FLEECE BACK (ADHERED) (MECHANICALLY ATTACHED: 20 YR MAX)  
 TPO SELF-ADHERING (ADHERED)

# MULEHIDE

TPO: MULEHIDE 2-PIECE SNAP ON COMPRESSION  
EDGE METAL

WHEN THE SYSTEM TYPE AND PROJECT DESIGN PERMIT, THIS DETAIL IS  
ACCEPTABLE FOR : **MAXIMUM 30 YEAR WARRANTY**

**DETAIL NO.:**  
**TP-EM-C116**

REVISION DATE: 8/24/2026