# 10 or 15 Year Warranty Design Summary

"The name trusted in roofing since 1906"

# **TPO - Mechanically Attached**



Revision Date: April 25, 2019

All products specified for this roofing system must be manufactured or approved by Mule-Hide Products Co. This criteria is limited to buildings of 100' in height or less, located in urban or suburban exposure areas. Not applicable for coastal or high wind areas.

#### Membrane

- 1. 0.045" or 0.060" or 0.080" thick Mule-Hide Reinforced TPO
- 2. 45-mil membrane, crease all 'T' joints with roller while still hot, see- Detail MHT-UN-105A.
- 3. 60-mil or 80 mil membrane, and warranties longer than15 years, overlay all "T" joints with TPO Non-Reinforced Flashing Membrane with heat welded seams Detail MHT-UN-105B.
- 4. All Field/Wall seam transitions on all membrane thicknesses must be overlaid with TPO Non-Reinforced Flashing Membrane with heat welded seams as shown in Detail MHT-UN-105C.
- 5. All field seams must be heat welded.

**Deck Type / Typical Fastener - Refer to Mule-Hide Specifications for minimum pullout criteria.** 

Roof Deck	Roof Height	Max Sheet Width	Max Fastener Spacing	Fastener (1) (2)	Seam Plate (5)
Steel - Min 22 ga.	Up to 60'	12'	6" OC	HDP (#14)	2.4"
		10' or 8'	12" OC		
	61' to 100'	12', 10' or 8'	6" OC		
Metal Panel Roofs, steel < 22 ga.	Contact Mule-Hide Technical Department prior to starting work. (system may not qualify for warranty)				
	Lin to CO	12'	6" OC	-	
Wood Plank - Min 2x or	Up to 60'	10' or 8'	12" OC	LIDD (#4.4)	0.4"
Plywood - Min 23/32"	0.41 4 4 0.01	12' or 10'	6" OC	HDP (#14)	2.4"
-	61' to 100'	8'	12" OC		
Plywood - Min 19/32"	Up to 60'	10' or 8'	12" OC		
	0.41.44.001	10'	6" OC	HDP (#14)	2.4"
	61' to 100'	8'	12" OC	, ,	
1X Plank or Plywood – Min 15/32"	Up to 60'	10'	6" OC		2.4"
	-	8'	12" OC	HDP (#14)	
	61' to 100'	8'	6" OC		
OSB	Contact Mule-Hide Technical Department prior to starting work. (system may not qualify for warranty)				
Structural Concrete - Min 2,500 psi	Up to 60'	12', 10' or 8'	12" OC		
	61' to 100'	12' or 10'	6" OC	HDP (#14)	2.4"
		8'	12" OC		
Insulating Concrete Gypsum Concrete Cementitous Wood Fiber & Other	Contact Mule-Hide Technical Department prior to starting work. (system may not qualify for warranty)				

### Notes:

- 1. Heavier gauge fasteners may be required to meet Factory Mutual or code requirements.
- 2. Other fasteners may be considered, submit request to Mule-Hide prior to bidding.
- 3. Mechanically attached systems are not allowed over Oriented Strand Board (OSB) decks without prior approval by the Mule-Hide Technical Department. Mule-Hide will not issue system warranties on "As-Built" projects where Mule-Hide did not grant approval prior to job start.
- 4. Contact Mule-Hide Technical Department for other roof decks or non-standard roof decks.
- 5. 3" Insulation Plates are NOT approved for use to fasten membrane.

## 10 or 15 Year Warranty Design Summary

## TPO – MECHANICALLY ATTACHED

## Slope Requirement/Drainage

- 1. Positive drainage required (no ponding 48 hours after a rain)
- 2. 1/4" per horizontal foot preferred
- 3. 1/8" slope with sufficient number of drains and crickets/saddles may be considered

## **Construction Type**

- 1. New Construction
- 2. Reroof Full tear off of existing roofing down to deck
- 3. Recover Over existing roofing system or existing insulation (all wet materials removed)

## Insulation/Overlayment - Mechanical Attachment into Standard Roof Decks\*

Insulation Type or Overlay		Board Size	
		4' x 8'	
Approved Polyisocyanurate - Min 1.0" thick (top layer) - Min 20 psi	4	6	
Approved Polyisocyanurate - Min 2.0" thick (top layer) - Min 20 psi	4	5	
Extruded Polystyrene - Min 1.0" thick - Min 25 psi	4	6	
HD Fiberboard - Min 1/2" thick- Installed over Approved Insulation		6	
Dens Deck Prime - Min 1/4" thick - Installed over Approved Insulation		6	

#### \*NOTES:

- 1. Gypsum board or suitable base sheet may be approved as needed to meet required fire code.
- 2. Consult Specification Manual for list of approved insulations for use under overlayment.
- 3. Contact Mule-Hide Technical Department for Polyisocyanurate less than 1.5" in thickness.
- 4. Certain codes may require additional fastening requirements.
- 5. System warranties require the use of Mule-Hide labeled components, products supplied by Mule-Hide or approved in writing by Mule-Hide prior to the start of the project.

## Insulation/Overlayment - Adhesive Attachment

1. **Mule-Hide Helix® MAX Low-Rise Adhesives**. Refer to the specifications and appropriate Helix® Max Product Data Sheet for acceptable insulations, substrates, and bead spacing.

#### **Metal Accessories**

- 1. All Metal copings, gravel stops, fascia, and drip aprons must be installed according to Mule-Hide approved details.
- 2. Conventional metal edge details that require flanges to be 'stripped in' must use TPO Cover Tape or White EPDM Cured Cover Tape (Mate-Line Tape).
- 3. All Metal Scuppers must have welded (soldered) seams.
- 4. Metal accessories provided by Mule-Hide will be included in System warranties.

#### Other Requirements

- 1. No 'As-Built' projects. All projects are to be reviewed and approved prior to installation.
- 2. Shop drawings must include all pertinent details.
- 3. Contact Mule-Hide Technical Department for specific code requirements such as Florida NOA, Factory Mutual (FM) or Underwriters Laboratory (UL).

## **Perimeter Enhancement Widths - Number Required**

Building Height	Perimeter Sheets
0 to 34 feet	Minimum of one (1) perimeter enhancement width
35 to 69 feet	Minimum of two (2) perimeter enhancement widths
70 to 100 feet	Minimum of two (2) perimeter enhancement widths (wind zones up to 80 mph)
70 to 100 feet	Contact Mule-Hide Technical Department for wind zones over 80 MPH
Over 100 feet	Contact Mule-Hide Technical Department

## 10 or 15 Year Warranty Design Summary

## **TPO - MECHANICALLY ATTACHED**

## Perimeter Enhancement - Width Dimension

Width of	Width of Perimeter Enhancement			
Field Sheet	Half Sheets	10" RUSS	Plates/Fasteners Through Membrane	
8'	4'	4'	4'	
10'	6'	5'	5'	
12'	6'	6'	6'	

## **NOTES:**

- 1. This is a summary of the Mule-Hide TPO Mechanically Attached System Specification, as written in the Mule-Hide TPO Specification Manual. Refer to Mule-Hide TPO Specification Manual for complete specification and details.
- 2. The information contained in this document is general information. Requirements may be different for each specific job based on the conditions of each building. Always contact Mule-Hide Technical Department to review the specific job conditions prior to bidding the project.