NOTF:

IF SHEETMETAL IS TO BE INCLUDED IN THE WARRANTY, CONTRACTOR MUST USE MULE—HIDE METAL PRODUCTS. REFER TO DETAILS MHSM—6050, MHSM—6052, MHSM—6054A & B, OR MHSM—6056...

CONTINUOUS CLIP FASTENED 12" O.C. MAX., WHEN NEEDED

EXISTING METAL CAP REMOVED AND RESET. ADDING A CONTINUOUS CLIP MAY BE NECESSARY

GROMMETTED FASTENER 12' O.C. MAX

TPO REINFORCED MEMBRANE FULLY ADHERED WITH M—H TPO BONDING ADHESIVE — SEE NOTE 3

M—H 2.4" SEAM PLATES AND HDP OR EHD FASTENERS, 12" O.C. MAX (SEE NOTES 1 & 4)

MINIMUM 1—½" HOT AIR WELD BEAD IRED

SEE NOTE 2

ROOF DECK→

APPROVED INSULATION -

NOTES:

- 1. POSITION SEAM PLATES 1/2" TO 1" FROM EDGE OF DECK MEMBRANE.
- 2. APPROXIMATELY 1/8" DIAMETER BEAD OF CUT-EDGE SEALANT IS REQUIRED ON CUT EDGES OF TPO REINFORCED MEMBRANE.
- 3. WHEN COUNTERFLASHING IS USED FOR TERMINATION, BONDING ADHESIVE IS NOT REQUIRED WHEN FLASHING HEIGHT IS 12" OR LESS. WHEN COPING OR A TERMINATION BAR IS USED, ADHESIVE MAY BE ELIMINATED WHEN FLASHING HEIGHT IS 18" OR LESS.
- 4. ON MECHANICALLY FASTENED SYSTEMS, MH HDP OR EHD FASTNERS AND 2.4" SEAM PLATES ARE REQUIRED AS A MINIMUM. CONTACT MULE—HIDE FOR TPO REINFORCED MEMBRANE FASTENING CRITERIA AND PROPER FASTENERS FOR EACH DECK TYPE.

MULE-HIDE PRODUCTS CO., INC.

PARAPET WALL EXISTING COPING CAP SYSTEMS:

ALL TPO SYSTEMS

DETAIL NO.:

MHT-UN-302

TPO REINFORCED MEMBRANE

REVISION DATE: 10/2013