



NOTES:

1. ON MECHANICALLY ATTACHED SYSTEMS, FASTEN TPO REINFORCED FIELD MEMBRANE (NOT SHOWN) 12" O.C. MAX. AROUND THE BASE OF THE BEAM.
2. WOOD BLOCKING MUST BE EMBEDDED IN A LAYER OF M-H UNIVERSAL SINGLE PLY SEALANT PRIOR TO FLASHING.
3. APPROXIMATELY $\frac{1}{8}$ " DIAMETER BEAD OF CUT-EDGE SEALANT IS REQUIRED ON CUT EDGES OF TPO REINFORCED MEMBRANE.

**MULE-HIDE
PRODUCTS CO., INC.**

I-BEAM SUPPORT FLASHING

**SYSTEMS:
ALL TPO SYSTEMS**

DETAIL NO.:

MHT-UN-523

REVISION DATE: 10/2013